

APPENDIX - VIII


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 1167

Date : 20/5/2026

It is certified that an inspection team headed by Devesh Chandra
Chemist (Name of Officers
with designation) from P.H. Division Bihar Sharif (Name of
Department/Office) inspected the All Saints' School
Nepura, Silao, Nalanda (Name & Address of
the School) on 20/5/2026 and found that the All Saints'
School Nepura Silao Nalanda (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year.

Signature with Seal : 

Name

: Raghendra Kumar

Designation

: Executive Engineer

कार्यपालक अभियन्ता
लोक स्वास्थ्य प्रमण्डल बिहारशरीफ
(नालन्दा)

To

All Saints' School
Nepura, Silao
Nalanda.

(Name & Address of the Institution)

Government of Bihar

Public Health Engineering Department

Water Quality Report


Division Name: Public Health Engineering Division, Biharsharif & Hilsa

District Name: Nalanda

Sample Collected by : - Ref no-ALL/139-26/08 VIKAS SINGH

Date of Sampling :- 18/05/2026

Sl. No.	Block	Panchayat	Village	Habitation	Location of Source	Test result														Source of Water
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
1	SILAO	NAGAR PANCHAYET	NEPURA	NEPURA WARD-1	ALL SAINTS SCHOOL NEPURA SILAO	7.62	0.46	490	318	150	40	12	40	160	0.12	<1.0	10.6	0.562	Tap water	
Desirable Limit						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	-	
Permissible Limit* in absence of alternate source						NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	-	


Chemist
20/5/26
Public Health Division, Biharsharif
(Nalanda)